

STATE OF NEBRASKA
NEBRASKA POWER REVIEW BOARD

Received
State of Nebraska
Power Review Board
Filed at 10:10am This 13
day of December 20 24
By: Rebecca Hawken
Title: Business Manager

IN THE MATTER OF THE APPLICATION OF,) Application for authority to construct or
) acquire an electric generation facility (ies)
City of Kimball) and/or related facility (ies).
223 S Chestnut Street)
Kimball, NE 69145) Application No.: PRB- assigned by PRB
Kimball Municipal Power Plant) Applicant File No.: assigned by applicant
_____)

4043-G

The City of Kimball, Nebraska applies to the Nebraska Power Review Board for an order authorizing it to construct or acquire electric generation facilities and/or related facilities in Kimball County, Nebraska, as hereinafter set forth below:

- (1) Description of proposed electric generation facilities:
 - A. Size of Unit: 8 Megawatts (MW)
 - B. Location of alternate locations: Not Applicable
 - C. Type of unit or alternate types: Caterpillar 3516 2000kw Standby Generators
 - D. If nuclear, type of reactor: Not Applicable
 - E. Have engineering feasibility studies been completed in regard to this facility? Yes X
No . If so, has a copy of the same been filed with the Nebraska Power Review Board? Yes No X
 - F. Has a consulting engineer for design and construction management been retained?
Farris Engineering has been hired by the City of Kimball's contractor NMC CAT, project manager Greg Donahoe, NMC, 11002 Sapp Brothers Drive, Omaha NE 68138.

- (2) Overall project schedule:
 - A. Estimated completion date of all engineering studies: 3/2024
 - B. Estimated date of commencement of construction: 12/2024
 - C. Estimated date the facility will engage in commercial operation: 2nd Quarter, 2025

- (3) Total Estimated Cost:
 - A. Total cost of generation station: \$4,968,837
 - B. Total cost of substations and switch yards or any other related facilities, not including transmission lines: Not Applicable
 - C. Total estimated cost: \$4,968,837
 - D. How is the proposed facility to be financed:
Electric Department budgeted revenue and municipal bond funds.

(4) Description of related facilities:
The interconnection of the new generation facility will require cabling and 1200 amp bus-tie circuit breaker section with the appropriate bus differential protection for the existing 15kV switchgear which is located in the existing substation building located immediately adjacent to the new generation facility which is located on the same property and adjacent to the old generation facility.

(5) The owners of electric generation facilities, electric transmission lines, and/or related facilities, and any other persons or organizations known to the applicant whom the applicant believes to be interested in this application are:


Appendix C:
Revised 2-29-12

Western Area Power Administration (WAPA) have been contacted regarding this facility as the existing substation is powered from their 115 kV bus located South of Kimball. Due to this being a replacement for the existing outdated generation, they did not require the City of Kimball to go through any study process. We have remained in contact with WAPA to ensure that we are installing acceptable material to meet their metering requirements.

(6) Waivers and consents from the following are attached: We are in constant contact with WAPA to maintain compliance with their requirements.

(7) The proposed electric generation facilities and/or related facilities will serve the public convenience and necessity, and the applicant can most economically and feasibly supply the electric service resulting from the proposed constructing or acquisition without unnecessary conflict and duplication.

Dated this 21st day of November 2024



Signature of preparer

By: Annette Brower
Title: City Administrator
Address: 223 S Chestnut St
Kimball, NE 69145



City of Kimball
223 S Chestnut
Kimball, NE 69145
Office: (308) 235-3639
Fax: (308) 235-2971
www.kimballne.org

11/21/2024

Annette Brower, City Administrator
City of Kimball
223 S Chestnut Street
Kimball, NE 69145


State of Nebraska Power Review Board,

Based on the recent change in the State of Nebraska Statute 70-1012(2)(a), we are respectfully submitting this document along with our application to show compliance with Statute 70-1012(2)(a).

As the City Administrator of the City of Kimball, Nebraska, per the additional documentation submitted to the City of Kimball dated 10/29/24 from PowerTech, the City can confirm and certify that to the best of our knowledge none of the requested materials, electronics, or other components ordered in association with the 3516 CAT engines were manufactured by a foreign government or foreign nongovernment person determined to be a foreign adversary as previously defined within section 15 CFR 7.4 which has been redesignated to 15 CFR 791.4.

Sincerely,

Annette Brower
City Administrator
City of Kimball



PRB-4034

“Small towns have their own heartbeat, no matter how many people come and go.” - unknown



2614 Railroad Highway
Council Bluffs, IA 51503

10/29/24
Annette Brower
City Administrator
City of Kimball
abrower@kimballne.org
308.235.3639 (office)
308.230.0498 (cell)

To whom it may concern:

Based upon a recent change in the State of Nebraska Statute §70-1012(2)(a), we understand your need to comply with the statute and that we play a part of helping you with compliance.


As a generator supply company for the City of Kimball. We can confirm and certify that to the best of our knowledge none of the 3516 Cat engines were manufactured by a foreign government or foreign nongovernment person determined to be a foreign adversary as previously defined within section 15 CFR 7.4 which has been redesignated to 15 CFR 791.4.

Sincerely,

Pat Henry



2614 Railroad Highway
Council Bluffs, IA 51503
Phone (712) 256-8702
Cell (402) 658-3479



PRB-4034